

## ELECTRICAL TESTING CENTER

(विद्युत परीक्षण केंद्र)

2<sup>nd</sup> Floor, A-8, Devyaninagar, Kaladarshan Char Rasta, Waghodia Road, VADODARA – 390025

Mo: +91 9537372370, E-mail: etc@etcglobal.in, www.etcglobal.in

## TEST REPORT

Page 1 of 1

Customer Name & Address

Litmus Industries Limited  
Ramesh Tower, Tripureshwar  
Kathmandu, Nepal

Report No. : VPK-2324-024 /3

Date : 27-06-2023


Customer Ref. No. : Letter

Date : 19-06-2023

| Date of Sample Receipt | Start date | End date   |
|------------------------|------------|------------|
| 15-06-2023             | 20-06-2023 | 21-06-2023 |

Sample Description

Paper Insulated Rectangular Copper Conductor  
Thickness 4.5 x Width 7.0 mm



Reference standard : Customer specification, generally as per IS 13730-Pt 27

Tests carried out : Electrical Resistance, Dimensions, Elongation

| Sr. No. | Cl. No. | Tests  | Specified Limit | Obtained value                   | Remarks |
|---------|---------|--|-----------------|----------------------------------|---------|
| 1.      | -       | Electrical Resistance, Ohm/rntr<br>-Corrected @ 20°C   |                 | 0.0005249                        |         |
| 2.      | -       | Dimensions, mm<br>- Thickness - Bare Size<br>- Width - Bare Size<br>- Thickness - Covered Size<br>- Width - Covered Size |                 | 4.491<br>7.022<br>5.191<br>7.715 |         |
| 3.      | -       | Elongation, %  |                 | 40                               |         |

Authorised Signatory  
Nilesh Pandya

## Notes :

- This report relates only to above particular sample received for testing in good condition and the tests asked by the client.
- This report is not to represent wholly or in part as an evidence for any legal purpose or any publication purpose.
- Reproduction of this report requires prior permission in writing from Director, Electrical Testing Center, Vadodara.
- Excess sample, if any, will be scrapped off after 30 days from the date of this test certificate, unless otherwise specified.
- Vadodara, India will be the exclusive jurisdiction in view of resolution of any dispute.
- Customer shall seek support from ETC for verification of authenticity of photocopied or reproduce test report issued by ETC.